



# 3415 Series

4" Heavy Commercial

Thermally Improved Single Slider w/Blinds

## SECTION 08520 ALUMINUM WINDOWS

SERIES 3415 Thermal HS-AW/HC \_\_\_ Grade Single Sliding Windows

### PART 1 GENERAL

#### 1.01 Work Included

- A. Furnish and install aluminum architectural windows complete with hardware and all related components as shown on drawings and specified in this section.

#### Insert 3415 Series Thermal.

- B. All windows shall be Winco (3415) HS-AW/HC \_\_\_\_\_. Other manufacturers requesting approval to bid their product as an equal must submit the following information fifteen days prior to close of bidding.
  - 1. A sample window (size and configuration) as per requirements of architect.
  - 2. Detail cuts and product data.
  - 3. Test reports documenting compliance with requirements of section 1.05.
- C. Glass and Glazing
  - 1. All units shall be factory glazed.

#### 1.02 Related Work


- A. Section 08400 - Entrance and Storefronts
- B. Section 08480 - Balanced Door Assemblies
- C. Section 08640 - Glazed Patio Doors
- D. Section 08652 - Replacement Windows
- E. Section 08900 - Glazed Curtain Walls
- F. Section 08960 - Slope Glazing System
- G. Section 07900 - Caulking and Sealant

#### 1.03 Items Installed But Not Furnished

#### 1.04 Items Installed But Not Furnished

#### 1.05 Testing and Performance Requirements

- A. Test Units
  - 1. Air, water, and structural test unit shall conform to requirements set forth in ANSI/AAMA/NWDA 101/I.S.2-97.
- B. Test Procedures and Performances
  - 1. All windows shall conform to ANSI/AAMA/NWDA 101/I.S.2-97 requirements for referenced window type in section 1.01B. In addition, the following specific performance requirements shall be met.
  - 2. Air Infiltration Test
    - a. With window sash and ventilators closed and locked, test unit in accordance with ASTM E 283, at static air pressure of 6.24 psf.
    - b. Air infiltration shall not exceed .3 cfm per square foot.
  - 3. Water Resistance Test
    - a. With window sash and ventilators closed and locked, test unit in accordance with ASTM E 331, at static pressure difference of \_\_\_\_ psf.
    - b. There shall be no uncontrolled water leakage.
  - 4. Uniform Load Deflection Test
    - a. With window sash and ventilators closed and locked, test unit in accordance with ASTM E 330, at a static air pressure difference (positive and negative) of \_\_\_\_ psf.
    - b. During the course of the test, no member shall deflect more than 1/175 of its span.
  - 5. Uniform Load Structural Test
    - a. With window sash and ventilators closed and locked, test unit in accordance with ASTM E 330 at a static air pressure difference of \_\_\_\_ psf.
    - b. At conclusion of test there shall be no glass breakage, permanent damage to fasteners, hardware parts, support arms or actuating mechanisms, nor any other damage which would cause the window to be inoperable.
  - 6. Condensation Resistance Test (CRF)
    - a. With window sash closed and locked, test unit in accordance with AAMA 1503.1.
    - b. Condensation Resistance Factor (CRF) shall not be less than \_\_\_\_.



# 3415 Series

## 4" Heavy Commercial

### Thermally Improved Single Sliding w/Blinds

7. Thermal Transmittance Test (Conductive U-Value)
  - a. With window sash closed and locked, test unit in accordance with AAMA 1503.1.
  - b. Conductive thermal transmittance (U-Value) shall not be more than \_\_\_\_ BTU/hr/sf per degrees F.
8. Life Cycle Test
  - a. Tested in accordance with AAMA 910, there shall be no damage to fasteners, parts, support arms, activating mechanisms, or any other damage, which would make the window inoperable. Subsequent air infiltration and water resistance tests shall not exceed specified requirements.

\*=For certified test reports consult Winco.

#### 1.06 Quality Assurance

- A. Provide test reports from AAMA accredited laboratory certifying the performance as specified in Section 1.05.
- B. Test reports shall be accompanied by the window manufacturer's letter of certification stating that the tested window meets or exceeds the afore mentioned criteria for the appropriate ANSI/AAMA/NWDA 101/I.S.2-97.

#### 1.07 References

#### 1.08 Submittals


- A. Contractor or window manufacturer shall submit shop drawings, finish samples, test reports, and warranties, per requirements of architect.
  1. Shop Drawings: Include typical unit elevations, full or half-scaled detail sections and typical installation details. Include type of glazing, screening, and window finish.
  2. Product Data: Manufacturer's specifications, recommendations and standard details for window units.
  3. Samples of materials may be requested without cost to owner, i.e. frame sections, corner samples, mullions, extrusions, anchors, and glass.

#### 1.09 Delivery, Storage, and Handling

- A. Store and handle windows and other components in strict compliance with manufacturer's instructions.
- B. Protect units against damage from the elements, construction activities and other hazards before, during, and after installation.

#### 1.10 Warranties

- A. Total Window System
  1. The responsible contractor shall assume full responsibility and warrant for one year the satisfactory performance of the total window installation which includes that of the windows, hardware, glass (including insulated units), glazing, anchorage and setting system, sealing, flashing, etc. as it relates to air, water and structural adequacy as called for in the specifications and approved shop drawings.
  2. Any deficiencies due to such elements not meeting the specifications shall be corrected by the responsible contractor at his expense during the warranty period.



# 3415 Series

## 4" Heavy Commercial

### Thermally Improved Single Slider w/Blinds

#### PART 2 PRODUCTS

##### 2.01 Materials

- A. Aluminum
  - 1. Extruded aluminum shall be 6063-T6 alloy and tempered, with a tensile strength of 24,000 PSI.
- B. Hardware
  - 1. Extruded aluminum auto-spring catch shall be provided at the jamb of the operating sash.
  - 2. All operating roller assemblies shall consist of steel ball bearing rollers and pin with nylon tires in a heavy nylon housing.
- C. Weatherstrip
  - 1. Each vent shall have one row of heavy fin seal wool pile weather stripping and one row of ridged vinyl installed in specially designed weather strip pocket in the extrusion.
- D. Thermal Barrier
  - 1. All exterior aluminum shall be separated from interior aluminum by ridged, structural pour in place thermal barrier. For purposes of this specification, a structural thermal barrier is defined as a system that shall transfer shear during bending and, therefore, promote composite action between the exterior and interior extrusions.
  - 2. Specified hardware shall not bridge the thermal barrier.
- E. Glass
  - 1. Monolithic glass shall be ( )

##### 2.02 Fabrication

- A. General
    - 1. Mechanical fasteners and hardware items shall not bridge thermal barriers. Thermal barriers shall align at all frame and vent corners.
  - B. Frame
    - 1. All aluminum frame extrusions shall have a minimum wall thickness of .063.
    - 2. Main frame sill members shall have a minimum wall thickness of .094.
    - 3. The main frame depth shall not be less than 4"
    - 4. Frame components shall be assembled by means of mechanical fastening with screws. Joinery to be sealed with small joint sealant.
  - C. Ventilator and Access Sash
    - 1. All sash frame extrusions shall have a minimum wall thickness of .080.
    - 2. Depth of the vent frame shall be not less than 1-11/16".
    - 3. Each corner shall be assembled by means of mechanical fastening with screws. Joinery on vent is sealed with small joint sealant.
    - 4. Each vent shall have one row of heavy fin seal wool pile weather-stripping and one row of ridged vinyl installed in specially designed weather strip pocket in the extrusion.
    - 5. Each access sash shall have one row of heavy fin seal wool pile weather-strip and one row of non-shrinking durometer Santoprene® weather-stripping.
  - D. Blinds
    - 1. Head rail shall be 0.625" wide x 0.650" high x 0.050" thick with bottom rail being .0625" wide x 0.375" high x .050" thick of 6063-T5 extruded aluminum alloy and temper with a baked on polyester powder coat finish conforming to AAMA Specifications #603.8-1985.
    - 2. Ladder cord locations shall not exceed 6" from the end of the slot or 24" apart.
    - 3. Tilt control knob designed with slip feature to minimize damage due to over tilting of blind.
    - 4. Removable key operated knobs and angled tilt control knobs, optional.
  - E. Screens (**Applicable only to windows requiring screens**)
    - 1. Extruded screen frames shall be fabricated from aluminum 6063-T6.
      - a. Screen mounting holes shall be pre-drilled at the factory.
      - b. Screen mesh shall be (enter aluminum, fiberglass, or stainless steel).
      - c. Screen mesh shall be so installed that the cloth may be easily replaceable.
- OR-**
- 1. Winco's 1000 Series hinged security screen with perforated steel sheet.
- F. Glazing
  - 1. All exterior units shall be structurally glazed with butyl tape and silicone cap bead.



# 3415 Series

4" Heavy Commercial

Thermally Improved Single Slider w/Blinds

2. All access sash are marine glazed using wrap around glazing vinyl.
- G. Finish
  1. Anodic
    - a. Finish all exposed areas of aluminum windows and components with electrolytically deposited color in accordance with Aluminum Association Designation AA-M10-C22-( \* ). Color is to be ( ).

**Available colors are clear, light bronze, medium bronze, dark bronze, and black.**

| <b>AA Designation</b> | <b>Description</b>      | <b>Mills</b>   | <b>AAMA Guide Spec.</b> |
|-----------------------|-------------------------|----------------|-------------------------|
| * A41                 | Class I Clear Anodized  | 0.7 or Greater | 611-98                  |
| * A31                 | Class II Clear Anodized | 0.4 or Greater | 611-98                  |
| * A44                 | Class I Color Anodized  | 0.7 or Greater | 611-98                  |
| * A34                 | Class II Color Anodized | 0.4 or Greater | 611-98                  |

**-OR-**

1. Painted
  - a. Finish all exposed areas of aluminum windows and components with ( ). Color is to be ( ).
    - (1) Duranar® = (70% Kynar) AA-M12-C42-R1X & AAMA 2605-98 & ASCA 96
    - (2) Fluropon® = (70% Kynar) AA-M12-C42-R1X & AAMA 2605-98 & ASCA 96
    - (3) Acroflur® = (50% Kynar) AA-M12-C42-R1X & AAMA 2604-98
    - (4) Acrodize® = (50% Kynar) AA-M12-C42-R1X & AAMA 2604-98

## **PART 3 EXECUTION**

### **3.01 Inspection**

- A. Job Conditions
  1. Verify that openings are dimensionally correct and within allowable tolerances. Openings must be plumb, level, and clean. Provide a solid anchoring surface that is in accordance with approved shop drawings.

### **3.02 Installation**

- A. Use only skilled craftsmen for work to be done in accordance with approved shop drawings and specifications.
- B. Set square and level aligning window faces in a single plane for each opening. Windows and materials must be set square and level. Adequately anchor window so when subjected to normal thermal movement, specified building movement, and specified wind loads, so windows will maintain a permanent position.
- C. Adjust windows for proper ease of operation after installation has been completed.
- D. Contractor furnish and apply sealant, per manufacturers recommendations, to provide a weather tight installation at all opening perimeters. Wipe off excess material and leave all exposed surfaces and joints clean and smooth.

*(Winco recommends window flashings, sub-sills and end dams on all window installations).*

### **3.03 Protection and Cleaning**

- A. After completion of window installation, windows shall be inspected, adjusted, and left in working order. Windows shall be left clean, free of labels, dirt, etc. Protection from this point shall be the responsibility of the building occupant.

*(Windows are a finished product and need to be treated carefully as a finished product).*

*Santoprene is a registered trademark of Advanced Elastomer Systems, Fluropon is a registered trademark of The Valspar Corp. Acroflur and Acrodize are trademarks of The Valspar Corporation. Duranar is a registered trademark of PPG Industries.*

*\*=The above specifications are subject to change without notice.*